

PUBLIC SAFETY DEPARTMENT[661]

Notice of Intended Action

Twenty-five interested persons, a governmental subdivision, an agency or association of 25 or more persons may demand an oral presentation hereon as provided in Iowa Code section 17A.4(1)"b."

Notice is also given to the public that the Administrative Rules Review Committee may, on its own motion or on written request by any individual or group, review this proposed action under section 17A.8(6) at a regular or special meeting where the public or interested persons may be heard.

Pursuant to the authority of Iowa Code section 100.1, the State Fire Marshal hereby gives Notice of Intended Action to amend Chapter 201, "General Fire Safety Requirements," Iowa Administrative Code.

The State Fire Marshal is authorized by Iowa Code section 100.1 to establish general requirements for fire safety and specific requirements for electrical installations. Other provisions of Iowa law authorize the Building Code Commissioner and the Electrical Examining Board to establish requirements for electrical installations. The Fire Marshal, the Building Code Commissioner, and the Electrical Examining Board have agreed to attempt to coordinate their rule making in this area and, as a general policy, to adopt succeeding editions of the National Electrical Code in a timely fashion. The amendment proposed herein would update the rules of the Fire Marshal to adopt by reference the National Electrical Code, 2008 edition. Similar rule makings are being undertaken by the Electrical Examining Board and the Building Code Commissioner.

A public hearing on this proposed amendment will be held on October 14, 2008, at 10 a.m. in the First Floor Public Conference Room (Room 125), State Public Safety Headquarters Building, 215 East 7th Street, Des Moines, Iowa 50319. Persons may present their views orally or in writing at the public hearing. Persons who wish to make oral presentations at the public hearing should contact the Agency Rules Administrator, Iowa Department of Public Safety, Wallace State Office Building, Des Moines, Iowa 50319, by mail; by telephone at (515)725-6185; or by electronic mail to admrule@dps.state.ia.us, at least one day prior to the public hearing.

Any written comments or information regarding this proposed amendment may be directed to the Agency Rules Administrator by mail or electronic mail at the addresses indicated by 4:30 p.m. on October 14, 2008, or submitted at the public hearing. Persons who wish to convey their views orally other than at the public hearing may contact the Agency Rules Administrator by telephone or in person at the Department office at least one day prior to the public hearing.

This amendment is intended to implement Iowa Code section 100.1.

The following amendment is proposed.

Amend rule 661—201.3(100) as follows:

661—201.3(100) Electrical installations. Electrical installations shall comply with the provisions of NFPA 70, National Electrical Code, ~~2005~~ 2008 edition.